



Reported:	14 January 2019	Published:	25 January 2019
Licensee:	Weston Aluminium Pty Limited	Address:	129 Mitchell Avenue, Kurri Kurri NSW, 2327
Frequency:	Annual	Event:	Annual
EPL No:	6423 (http://www.environment.nsw.gov.au/prpoeoapp)		

Qualifications related to stack emission monitoring

All testing and analyses are performed in accordance with NATA's accreditation requirements.

Monitoring Location	Date Sampled	Measured Levels			
		Pollutant	Measurement	Limit	Unit
Monitoring Point 4 (Stack 4)	09 Nov 2018	Total particulate	4.6	24	mg/m ³
Monitoring Point 14 (Stack 6)	03 Dec 2018	Total Particulate	32 ^{*1}	10 ^{*2}	mg/m ³
		Total oxides of nitrogen	81	NL	mg/m ³
		Carbon monoxide	3	NL	mg/m ³

NOTES:

Emission concentrations expressed at dry gas, 273 K and 101.3 kPa conditions.

*1 Value is corrected to 3% oxygen for direct comparison with the regulatory limit.

*2 Limit value is expressed at 3% oxygen reference.

Exceedances this period: Stack 6 Total Particulate (32 mg/m³, expressed at STP, dry, 3% O₂)