



<b>Reported:</b>	15 June 2016	<b>Published:</b>	16 June 2016
<b>Licensee:</b>	Weston Aluminium Pty Limited	<b>Address:</b>	129 Mitchell Avenue, Kurri Kurri NSW, 2327
<b>EPL No:</b>	6423	<b>Monitoring Frequency:</b>	Annual

**Qualifications related to water quality monitoring**

Regulatory limits are not defined in the Environmental Protection Licence (EPL) for water quality. First flush wetland waters, to which monitoring data below relate, are reused via an onsite reticulation system for site landscaping irrigation, and hence no off-site discharge occurs.

Monitoring Location	Date	Time	Measured Levels							Observations
			pH	Electrical Conductivity (µS/cm)	Suspended Solids (mg/L)	Aluminium (mg/L)	Cyanide (mg/L)	Fluoride (mg/L)	Oil & Grease (mg/L)	
Monitoring Point 12	07 June 2016	10:15	8.24	377	12	1.71	<0.004	16.2	<5	<b>Weather:</b> Fine, 16 °C, 62% RH, moderate winds NNW at 16 km/h. <b>Wetland level:</b> Approximately 70% <b>Sampler Observations:</b> Water clear, no odour. Moderate water height.

NOTES: Weather conditions sourced from Bureau of Meteorology (Cessnock Airport AWS (Station 061260))